T-24 energy and LEED energy modeling credits: Understanding the similarities and differences



5/5/2010

Gilleran Energy Management

Introduction

- We have 40 minutes to take a quick look at two similar but not identical processes
- Use California T-24-2005 performance energy budget in place of ANSI/ASHRAE/IESNA Standard 90.1-2007 approach to the LEED2009 NC EAcr1 Option 1 approach
- Assume that the audience is very familiar with building energy modeling and simulation tools and the California Non Residential ACM model

Agenda

- Brief overview of LEED point structure
- Review LEED program goals
 - LEED EAcr1 3 options to credits
 - LEED program is cost based not energy (kbtu/sqft/yr) based
 - How are T-24 and ANSI/ASHRAE/IESNA standards used in this context
- Where does the LEED energy modeling requirements differ with the T-24 procedures

LEED2009 NC point structure

	LEED2009	NC point	structure	has	changed.
--	----------	----------	-----------	-----	----------

 Now based on a possible 110 points instead of the old 69 points for LEED NCv2.2

	Sustainable Sites	26 points
	Water Efficiency	10 points
	Energy & Atmosphere	35 points
	 Double the possible impact now (32% total) 	
	Materials & Resources	14 points
	Indoor Environmental Quality	15 points
	Innovation & Design	6 points
_		

- Currently three approaches to achieving LEED credits
 - Option 1. Whole Building Energy Simulation up to 20 points
 - ANSI/ASHRAE/IESNA Standard 90.1-2007 energy budget
 - California T-24-2005 performance energy budget
 - Option 2. Prescriptive Compliance Path: ASHRAE
 Advanced Energy Design up to 1 point
 - Option 3. Prescriptive Compliance Path: Advanced Buildings "Core Performance" – up to 3 points

- CABEC members will typically focus on the Option 1 energy model approach
- It is important that the energy modeler download and be familiar with the rules that govern the baselines for both the California Energy Code and the ANSI/ASHRAE/IESNA standards.
- We find that using EnergyPro the energy modeler has an opportunity to look at T-24 and the 90.1 side by side.
 - Some of the inputs in EnergyPro are different for ASHRAE so be sure to make the appropriate adjustments.

- EA credit 1 up to 19 points
 - Exemplary Performance. New Buildings: 50%+ 1 additional credit
- EA credit 2. Onsite Renewable Energy up to 7 points
 - Renewable energy counts towards EA credit 1 energy performance
 - Exemplary Performance. New Buildings: 15%+ 1 additional credit
- EA credit 1 & 2 credits together represent
 - Total impact can be up to 25% of a LEED certification and definitely can in easily change a project one level of certification

- EA credit 1 & 2 credits together represent
 - Another opportunity for the CABEC consultant to add another scope of work that can have a large impact.
 - PG&E and other non profits have all sorts of solar classes to get energy consultants up to speed.
 - The solar analysis can be done to determine % of total building energy contribution, system sizing and form the basis for a solar RFP.

- Important difference in evaluating performance between T-24 and LEED
 - T-24 energy analysis and savings are in terms of energy ie Kbtu/SqFt/Year adjusted for TDV.
 - LEED EA credit 1 and 2 are based on energy savings in terms of dollars
 - Expect to use real tariffs (rate structure).
 - Exceptional method savings and additional energy use must be converted to dollars as well.
 - LEED credit documentation is a separate live Adobe document used to document all of the building energy usage.
 - Note this document alone can sometimes take up to 10-15 hours to complete depending on the project complexity. EP5 now has a document that can help simplify this process.

- T-24 energy standards covers basically the following and most measures are easily modeled in EnergyPro
 - Building envelope for spaces that are comfort conditioned
 - HVAC for occupant comfort
 - DHW for domestic water use
 - Lighting indoor and outdoor for people usage
- EA credit 1, Option 1 Whole Building Simulation takes the above measures and adds in the rest of the energy usage on a typical project that most CABEC members would now happily ignore

- Regulated (non-process) energy includes
 - Lighting (e.g., for the interior, parking garage, surface parking, facade, or building grounds, etc. except as noted above), heating, ventilating, and air conditioning (HVAC) (e.g., for space heating, space cooling, fans, pumps, toilet exhaust, parking garage ventilation, kitchen hood exhaust, etc.), and service water heating for domestic or space heating purposes.
- Process energy is considered to include
 - Office and general miscellaneous equipment, computers, elevators and escalators, kitchen cooking and refrigeration, laundry washing and drying, lighting exempt from the lighting power allowance (e.g., lighting integral to medical equipment) and other (e.g., waterfall pumps)
- Process energy must be at least 25% unless otherwise documented.
- Energy modeling tip: include as much of the building process energy in the energy model as possible to simplify documentation.

- Process loads must be identical for both the baseline building performance rating and the proposed building performance rating.
- Exceptional calculation method may be used to document measures that reduce process loads.
 - Documentation of process load energy savings must include a list of the assumptions made for both the base and proposed design, and theoretical or empirical information supporting these assumptions.

- What does this mean to you as the energy modeler?
 - Significant time and effort evaluating areas of the building energy use that you have not considered before. There may be areas in which you have no familiarity.
 - Much more coordination with design and construction team as well as the building owner to learn more about the anticipated building operation.
 - For instance you will need to determine outdoor lighting operation in order to determine what the overall impact of the lighting in relation to total building energy use as well as to determine energy savings.
 - Another good example is to determine how big an impact of a commercial kitchen might be in a facility that only uses the commercial kitchen 20 or so times a year. A winery is a good example of this issue.

 Here is an example of a summary calculation that includes regulated energy use that must go in the LEED template but is not calculated by EnergyPro

XYZ Production Facilities for XYZ Winery

Baseline Design Energy Cost Not Included in Computer Models

			Cost/Unit	
	Annual	Units of annual	of Energy	
Description	Energy Use	Energy	*	Total Cost
Electricity				
Regulated Exterior Lighting	2802	kWh	0.1833	\$521.69
Regulated Interior Lighting (Unheated Building)	45801	kWh	0.1833	\$8,395.32
				\$8,917.01
Proposed Design Energy Cost Not Included in	Computer Mo	dels		
Electricity				
	Annual	Unite of ennual	Coot/Unit	
	Annual	Units of annual	Cost/Unit	
Description	Annual Energy Use	Units of annual Energy	Cost/Unit of Energy	Total Cost
Description Regulated Exterior Lighting	Annual Energy Use 2683	Units of annual Energy kWh	Cost/Unit of Energy 0.1833	Total Cost \$499.21
Description Regulated Exterior Lighting Regulated Interior Lighting (Unheated Building)	Annual Energy Use 2683 38558	Units of annual Energy kWh kWh	Cost/Unit of Energy 0.1833 0.1833	Total Cost \$499.21 \$7,067.68
Description Regulated Exterior Lighting Regulated Interior Lighting (Unheated Building)	Annual Energy Use 2683 38558	Units of annual Energy kWh kWh	Cost/Unit of Energy 0.1833 0.1833	Total Cost \$499.21 \$7,067.68 \$7,566.89

* kWh Energy Cost from DOE-2 SIM output file: XYZ_LEED-Final-121009-Proposed-SIM.doc



 Here is an example of a summary calculation that includes non-regulated energy use that must go in the LEED template but is not calculated by EnergyPro

XYZ Production Facilities for XYZ Winery Baseline Design Energy Cost Not Included in Computer Models

Costs have been added to total in LEED EAc1 Table 1.8.1(b) and 1.8.2(b)

Description	Annual Energy Use	Units of annual Energy	Cost/Unit of Energy *	Total Cost			
Electricity							
Unregulated Exterior Lighting (Process)	3012	kWh	0.1833	\$552.10			
Unregulated Fermentation (Process)	2626	kWh	0.1833	\$481.35			
Unregulated Barrel Building Cooling/Fans (Process)	30453	kWh	0.1833	\$5,582.03			
Hot Water Loop Pump (Process)	226	kWh	0.1833	\$41.43			
				\$6,656.91			
Propane							
Process Water Heating Summer	385	therms	1.615	\$621.78			
Process Water Heating Winter	217	therms	1.885	\$409.05			
				\$1,030.82			
			Grand Total	\$7,687.73			

Summary

- The USGBC LEED program and the LEED energy credits are great opportunities for energy consultants to learn more about whole building energy modeling.
- There is also potentially greater liability in this consulting.
 - Owners are depending on your energy analysis to be correct and acceptable to the USGBC certification reviewers.
 - Because the LEED energy credits represent such a large percent of a building's LEED certification credits it is vital that the energy consultant understand the California energy code or ANSI/ASHRAE/IESNA standards as much or more than the prospective LEED reviewer.
 - The LEED review process is a closed system with little to no direct contact with the LEED reviewers. Keep this in mind when attempting to model something that may not be well understood.

LEED credits: T-24 & 90.1 modeling

•Questions?

Where to Get More Information

- USGBC: LEED 2009: Technical advancements to the LEED rating system
 - <u>http://www.usgbc.org/DisplayPage.aspx?CMSPageID=1971</u>
- California Energy Commission
 - NonResidential ACM Manual
- ASHRAE
 - ANSI/ASHRAE/IESNA Standard90.1-2007 User's Manual
- Gilleran Energy Management
 - Kevin P. Gilleran
 - LEED AP, CalCERTS, GPR, CEA, BPI, CEM, QCxP
 - 750A Davis Street, Santa Rosa CA 95401
 - office:707-528-7318, fax: 707-528-7325
 - Kevin@GilleranEnergy.com
 - www.gilleranenergy.com